

# Granite State Analytical, LLC

Main Office / Laboratory  
22 Manchester Rd. / Rt. 28  
Derry, NH 03038  
(603) 432-3044

Lab Contact: Donald A. D'Anjou, Ph. D., Laboratory Director

DATE PRINTED: 12/19/2011

CLIENT NAME: Skillings & Sons, Inc.  
CLIENT ADDRESS: 9 Columbia Dr  
Amherst, NH, 03031

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

SAMPLE ID#: 1112-00399-001  
SAMPLED BY: Skillings & Sons, Inc.  
SAMPLE LOCATION: Hollis School Dist, Site 008 Teachers Lounge-01681

DATE & TIME COLLECTED: 12/14/11 11:15 am  
DATE & TIME RECEIVED: 12/15/11 2:23 pm  
ANALYSIS PACKAGE: First Draw Copper/Lead  
RECEIPT TEMPERATURE: ON ICE 6.5 CELSIUS

Test Description	Results	Test Units	Test Fails	Analysis Method	Analyst	Date & Time Analyzed	MCL
Copper*	0.060	mg/L		EPA 200.7	WL	12/16/11 13:15	1.30 mg/L
Lead*	<0.005	mg/L		EPA 200.9	WL	12/19/11 13:22	0.015 mg/L

The results presented in this report relate to the samples listed above in the condition in which they were received.

**MCL = Maximum Contaminant Level**

\* NELAC Accredited Analysis  
A list of our certifications is available upon request.



A handwritten signature in black ink, appearing to read "Donald A. D'Anjou".

Donald A. D'Anjou, Ph.D.  
Laboratory Director

This analysis meets NELAC requirements except as noted.

This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical, LLC